

Larry Rayman  
Direct: 1-561-414-9696  
Fax: 1-561-892-0440  
Lray@GTI-power.com



2524 N Andrews Ave Ext  
Pompano Beach, FL 33064  
www.GTI-power.com

## GE Frame 5P Model MS5001P

### 23.4MW, 60HZ, Rating 29,600KVA

---

SEP 14 1978      TOTAL FIRED HOURS 227    37 MWH ONLY    GTI #5001

---

<u>DATE</u>	<u>INSP TYPE</u>	<u>TOTAL FIRED HOURS</u>	<u>TOTAL FIRED STARTS</u>
MAR 08 1980	COMBUST	4567	89
MAR 01 1982	HOT GAS PATH	9436	155
APR 04 1983	COMBUST	14727	196
JUL 14 1984	MAJOR	22705	222
APR 03 1986	COMBUST	33934	296
OCT 08 1988	MAJOR	45724	362
FEB 14 1990	COMBUST	51700	388
DEC 01 1990	HOT GAS PATH	58932	409
JAN 06 1992	COMBUST	65860	428
JAN 06 1993	MAJOR	71795	447
JAN 01 1994	COMBUST	76104	470
JAN 07 1995	HOT GAS PATH	82720	482
MAR 02 1996	CI & RRR	86464	492
APR 13 1997	MAJOR	92984	521

MAY 26 1998	COMBUST	100353	547
FEB 01 1999	HOT GAS PATH	104527	559
JAN 18 2000	COMBUST	108435	588
APR 05 2001	MAJOR	114449	599
MAY 08 2002	COMBUST	120654	630
MAY 19 2003	HOT GAS PATH	127434	657
JAN 26 2006	HOT GAS PATH	142828	710

Records show GT#1 shut down on 24 DEC 2006.

Total fired hours as of 24DEC 2006: 146198.1

Total fired starts as of 24DEC 2006: 722

1749 HOURS PAST DUE FOR MAJOR INSPECTION

## GE Frame 5P Model MS5001P

### 23.4MW, 60HZ, Rating 29,600KVA

---

AUG 08 1978      TOTAL FIRED HOURS 162    14 MWH ONLY    GTI#5002

---

<u>DATE</u>	<u>INSP TYPE</u>	<u>TOTAL FIRED HOURS</u>	<u>TOTAL FIRED STARTS</u>
MAY 03 1980	COMBUST	4634	77
MAY 28 1982	HOT GAS PATH	10643	136
SEP 05 1983	COMBUST	16404	153
SEP 01 1985	MAJOR	26070	217
SEP 04 1988	HOT GAS PATH	43252	338
DEC 27 1988	COMBUST	48992	356
DEC 26 1989	MAJOR	52902	385
DEC 29 1990	COMBUST	58178	405
JAN 02 1992	HOT GAS PATH	64645	446
JAN 03 1993	COMBUST	70742	473
FEB 03 1994	MAJOR	77741	495
NOV 03 1995	COMBUST	83517	526
MAY 15 1996	HOT GAS PATH	91796	575
JAN 12 1997	CI & RRR	94122	585
JAN 14 1998	MAJOR	101880	596
MAR 01 1999	COMBUST	108539	608
MAR 01 2000	HOT GAS PATH	115322	617

JUL 11 2001	COMBUST	124699	636
FEB 13 2002	MAJOR	128815	642

No records after 01 NOV 2006.

Total fired hours as of 01 NOV 2006: 153104.6

Total fired starts as of 01 NOV 2006: 742

COMBUSTION INSPECTION 17289 HOURS PAST DUE

HOT GAS PATH INSPECTION 14289 HOURS PAST DUE

HAS 5710 HOURS (238 DAYS) UNTIL MAJOR INSPECTION IS DUE

# GE Frame 5P Model MS5001P

## 23.4MW, 60HZ, Rating 29,600KVA

---

SEP 14 1978      TOTAL FIRED HOURS 227    37 MWH ONLY    GTI #5003

---

<u>DATE</u>	<u>INSP TYPE</u>	<u>TOTAL FIRED HOURS</u>	<u>TOTAL FIRED STARTS</u>
APR 01 1982	HOT GAS PATH	9387	
APR 06 1983	COMBUST	15396	168
MAR 08 1986	MAJOR	34060	258
FEB 23 1988	HOT GAS PATH	44580	298
JAN 03 1989	COMBUST	51624	320
DEC 25 1989	MAJOR	57951	339
FEB 20 1991	COMBUST	64868	376
DEC 22 1992	COMBUST	75749	405
MAR 01 1994	MAJOR	82441	414
FEB 08 1995	COMBUST	88279	429
APR 25 1996	HOT GAS PATH		
JAN 12 1997	CI & RRR	101452	473
MAR 28 1998	MAJOR	108060	492
JAN 04 2003	MAJOR	134647	602
MAR 08 2004	COMBUST	142205	619
FEB 26 2005	HOT GAS PATH	147907	637

No records after 22 JAN 2007.

Total fired hours as of 22 JAN 2007: 157962.5

Total fired starts as of 22 JAN 2007: 659

COMBUSTION INSPECTION 15757 HOURS PAST DUE

HOT GAS PATH INSPECTION 55 HOURS PAST DUE

HAS 6685 HOURS (279 DAYS) UNTIL MAJOR INSPECTION IS DUE